

Energy performance certificate (EPC)

Apartment 4 Wheatsheaf Works 57 John Street SHEFFIELD S2 4QS	Energy rating D	Valid until: 12 November 2035
		Certificate number: 9300-2630-9500-2575-6605

Property type Mid-floor flat

Total floor area 59 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](#) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, insulated (assumed)	Good
Window	Fully double glazed	Average
Main heating	Room heaters, electric	Very poor
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Excellent lighting efficiency	Very good
Roof	(another dwelling above)	N/A

Feature	Description	Rating
Floor	(another dwelling below)	N/A
Air tightness	(not tested)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 130 kilowatt hours per square metre (kWh/m²).

► [About primary energy use](#)

Smart meters

This property had **a smart meter for electricity** when it was assessed.

Smart meters help you understand your energy use and how you could save money. They may help you access better energy deals.

[Find out about using your smart meter \(<https://www.smartenergygb.org/using-your-smart-meter>\)](#)

How this affects your energy bills

An average household would need to spend **£1,397 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £449 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 2,817 kWh per year for heating
- 1,961 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces

6 tonnes of CO2

This property produces

0.7 tonnes of CO2

This property's potential production

0.7 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

► Do I need to follow these steps in order?

Step 1: High heat retention storage heaters and dual immersion cylinder and dual rate meter

Typical installation cost £1,200 - £2,400

Typical yearly saving £449

Potential rating after completing step 1

78 C

Advice on making energy saving improvements

Get detailed recommendations and cost estimates

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: [Home Upgrade Grant](#)
- Insulation: [Great British Insulation Scheme](#)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme](#)
- Help from your energy supplier: [Energy Company Obligation](#)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Andrew Sagar

Telephone 07903588299

Email orders@asbuiltenergysurveys.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Assessor's ID

EES/021302

Telephone

01455 883 250

Emailenquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration

No related party

Date of assessment

30 October 2025

Date of certificate

13 November 2025

Type of assessment► [RdSAP](#)


Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)[Give feedback \(<https://forms.office.com/e/KX25htGMX5>\)](#)[Service performance \(/service-performance\)](#)**OGL**

All content is available under the [Open Government Licence v3.0](#) (<https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/>), except where otherwise stated



© Crown copyright (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/>)